



Certificate of
Conformity
202330028/AA/00



Issued 23-10-2020

Replaces

Page

1 / 7

Kiwa FSS products declares that the listed product(s) complies with the Technical standards and specifications as indicated under Annex 2 of this certificate.

Product description:	IRIS Addressable Fire Alarm System
Trademark:	Teletek Electronics
Type designation:	IRIS
Hardware / Software:	- / -

Placed on the market under the name or trademark of:

Name of the manufacturer:	Teletek Electronics JSC
Address:	Srebarna Str. 14A
City:	1407 SOFIA
Country:	Bulgaria

This certificate is granted to:

Name of the certificate holder:	Teletek Electronics JSC
Address:	Srebarna Str. 14A
City:	1407 SOFIA
Country:	Bulgaria

Ron Scheepers
Managing director

Remarks and observations

The following conditions are applicable:

The following products have been involved in the compatibility assessment, as detailed in chapter 1.3 “*Scope of assessment*” of assessment report 200401719-001 (Ver. 3.00):

CIE**Fire Panels (EN 54-2 / EN54-4)**

Product ID	Description	Classification*
Teletek Electronics		
IRIS (1-4) L M		
IRIS (1-4) L P	Intelligent Analogue Addressable	1
IRIS (0) Repeater M	Interactive Fire Alarm Control Panel	
IRIS (0) Repeater P		

AUXILIARY DEVICES**Detectors (EN 54-5 / EN 54-7 / EN 54-17)**

Product ID	Description	Classification*
Teletek Electronics		
SensolRIS T110		
MAGPRO-HD1	Intelligent Analogue Addressable Fire	1
Belinda T110	Alarm Heat Detector	
SensolRIS S130		
MAGPRO-SD1	Intelligent Analogue Addressable Fire	1
Belinda S130	Alarm Optical Smoke Detector	
SensolRIS M140		
MAGPRO-HSD1	Intelligent Analogue Addressable Fire	1
Belinda M140	Alarm Heat and Optical Smoke Detector	
SensolRIS M140 IS		
MAGPRO-HSD1iM	Intelligent Analogue Addressable Fire	1
Belinda M140 IS	Alarm Heat and Optical Smoke Detector with built-in isolator module	
SensolRIS S130 IS		
MAGPRO-SD1iM	Intelligent Analogue Addressable Fire	1
Belinda S130 IS	Alarm Optical Smoke Detector with built-in isolator module	
SensolRIS T110 IS		
MAGPRO-HD1iM	Intelligent Analogue Addressable Fire	1
Belinda T110 IS	Alarm Heat Detector with built-in isolator module	
Vella M140	Intelligent Analogue Addressable Fire	1
	Alarm Heat and Optical Smoke Detector	
Vella S130	Intelligent Analogue Addressable Fire	1
	Alarm Optical Smoke Detector	
Vella T110	Intelligent Analogue Addressable Fire	1
	Alarm Heat Detector	
Vella M140 IS	Intelligent Analogue Addressable Fire	1
	Alarm Heat and Optical Smoke Detector with built-in isolator module	
Vella S130 IS	Intelligent Analogue Addressable Fire	1
	Alarm Optical Smoke Detector with built-in isolator module	

Vella T110 IS	Intelligent Analogue Addressable Fire Alarm Heat Detector with built-in isolator module	1
SensolRIS B124	Addressable Fire Base	1

Manual Call Points (EN 54-11 / EN 54-17)

Product ID	Description	Classification*
Teletek Electronics		
SensolRIS MCP150	Intelligent Analogue Addressable Fire Alarm Manual Call Point with built-in isolator module	1
MAGPRO-CPiM		
Belinda MCP150		
SensolRIS MCP150MR	Intelligent Analogue Addressable Fire Alarm Manual Call Point with built-in isolator module	1
Belinda MCP150MR		
SensolRIS MCP150PR	Intelligent Analogue Addressable Fire Alarm Manual Call Point with built-in isolator module	1
SensolRIS MCP150PB	Intelligent Analogue Addressable Fire Alarm Manual Call Point with built-in isolator module	1
Belinda MCP150PB		
Belinda MCP150PR		
SensolRIS MCP150 IP67		
MAGPRO-CPiM IP67	Intelligent Analogue Addressable Fire Alarm Manual Call Point with built-in isolator module	1
Belinda MCP150 IP67		

Warning Devices (EN 54-3 / EN 54-17 / EN 54-23)

Product ID	Description	Classification*
Teletek Electronics		
SensolRIS WS	Intelligent Analogue Addressable Fire Alarm Sounder	1
MAGPRO-WSS		
SensolRIS WSOU	Intelligent Analogue Addressable Fire Alarm Sounder	1
MAGPRO-WS		
Belinda WSOU		
SensolRIS WSOU IS	Intelligent Analogue Addressable Fire Alarm Sounder with built-in isolator module	1
MAGPRO-WSiM		
Belinda WSOU IS		
SensolRIS WSST	Intelligent Analogue Addressable Fire Alarm Sounder and Strobe	1
MAGPRO-WSS23		
Belinda WSST		
SensolRIS WSST IS	Intelligent Analogue Addressable Fire Alarm Sounder and Strobe with built-in isolator module	1
MAGPRO-WSS23iM		
Belinda WSST IS		
SensolRIS WSB IP65	Waterproof protected deep base	1
SensolRIS BSOU	Intelligent Analogue Addressable Fire Alarm base with built-in sounder	1
MAGPRO-DBS		
SensolRIS BSST	Intelligent Analogue Addressable Fire Alarm base with built-in sounder and strobe /flash/	1
MAGPRO-DBSS		

SF300	Conventional fire alarm outdoor sounder	1
SF3000		
SF400		
SF100 RSST	Conventional fire alarm sounder with strobe	1
Hera RSST		
Tera RSST		
Aura RSST		
SF100 RSND	Conventional fire alarm Sounder	1
Hera RSND		
Tera RSND		
Aura RSND		
SF100 WSST	Conventional fire alarm sounder with strobe	1
Hera WSST		
Tera WSST		
Aura WSST		

I/O modules (EN 54-17 / EN 54-18)

Product ID	Description	Classification*
Teletek Electronics		
SensolRIS MIO22	Module Inputs/ Outputs	1
SensolRIS MIO 04	Intelligent Analogue Addressable Fire Alarm Module with 4 outputs with built-in isolator module	1
MAGPRO-0i4OiM		
Belinda MIO40	Intelligent Analogue Addressable Fire Alarm Module with 4 inputs with built- in isolator module	1
SensolRIS MIO 40		
MAGPRO-4i0OiM		
Belinda MIO04	Isolator Module	1
SensolRIS MISO		
MAGPRO-iM	Intelligent Analogue Addressable Fire Alarm Monitored Output Module for Conventional Sounders with 4 inputs with built-in isolator module	1
SensolRIS MOUT		
MAGPRO-1OSiiM		
Belinda MOUT	Intelligent Analogue Addressable Fire Alarm Module with 2 inputs and 2 monitored outputs with built-in isolator module	1
SensolRIS MIO22M		
SensolRIS MIO22M		
IP55		
MAGPRO-2i2OiM M		
Belinda MIO22M		

Power supply (EN54-4)

Product ID	Description	Classification*
Teletek Electronics		
IRIS PS72	Back-up Power Supply Unit	1

Miscellaneous

Product ID	Description	Classification*
Teletek Electronics		
IRIS Printer	Thermal printer in a metal box	2

*** Classification options:**

- Component type 1: device performing EN54-1 defined functionality
- Component type 2: other types of devices connected to component type 1

Documentation lodged for this Certificate of Conformity

Test Reports:

- Telefication B.V.: 200401719-001 (Ver. 3.00), 22 July 2020

Product Documentation:

Technical Standards and Specifications

The product shows no non-compliances with:

EN 54-13:2017 + A1:2019

October, 2019

Applied Standards

Not Applicable

The product as described in this certificate includes the following type designations

- Product description: IRIS Addressable Fire Alarm System
- Trademark: Teletek Electronics
- Type designation: IRIS
- Hardware version: -
- Software version: -